

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0811:0131

CATEGORY: 7300 -- MISC. DEVICE/CONTROL UNIT ACCESSORIES

LISTEE: Federal Signal, 2645 Federal Signal Drive, University Park, IL 60466-3195
Contact: Sean Moloney (708) 587-3324 Fax (708) 534-4878
Email: smoloney@federalsignal.com

DESIGN: Model 27XST and FSEX general signaling strobe lights for use in hardous locations: Class I, Division 1, Group C and D; Class I, Division 2, Group A and B; Class II, Group E, F and G; and Class III. Refer to listee's data sheet for additional product description and operational considerations.

RATING: 24, 120, 240VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as general visual signaling strobe lights (non-fire alarm) for use with separately listed compatible fire alarm control units. For indoor and outdoor use. Enclosure is rated Type 4X. Not suitable for the hearing impaired applications. Refer to listee's Installation Instruction Manual for details.

NOTE:

*Rev. 02-03-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division